


DIAMOND INDUSTRIES AND LABORATORIES



All Type of Building And Highway Material Testing

NABL ACCREDITED TESTING LABORATORY, TC -5201

Drinking Water Test Certificate

Reg. No. -Mp-6004

Ro Type- -Dodo

Division And Ro Location- Gurukul Public School, Somna Road, Khair

Type Of Sample - Drinking Water

Date Of Sample Collection - 02-03-2025

Date Of Sample Testing -02-03-2025

Serial No. - 1849

Validity - One year

S.No.	Test Parameter	Test Method	Test Value	Requirement acceptable limit IS=10500-2012	Permissible limit in absence of alternate source
1	Colour,Hazen	IS:3025(Pt-4):1983	<5	5 Max	15 Max
2.	Odour	IS:3025(Pt-5):1983	Agreeable	Agreeable	Agreeable
3.	Taste	IS:3025(Pt-7,8):1983	Agreeable	Agreeable	Agreeable
4.	Turbidity	IS:3025(Pt-10):1983	0.3	1 Max	5 Max
5.	pH-Value	IS:3025(Pt-11):1983	7.48	6.5 to 8.5	No Relaxation
6.	Total Hardness	IS:3025(Pt-21):1983	196	200 Max	600 Max
7.	Chloride	IS:3025(Pt-32):1988	74	250 Max	1000 Max
8.	TDS	IS:3025(Pt-60):1984	462	500 Max	2000 Max
9.	Calcium	IS:3025(Pt-40):1991	35.30	75 Max	200 Max
10.	Residual Chlorine	IS:3025(Pt-26):1986	Nil	0.2 minimum	1 Max
11.	Iron	IS:3025(Pt-53):2003	0.06	0.3 Max	No Relaxation
12.	Fluoride	IS:3025(Pt-60):2006	0.1	1 Max	1.5 Max
13.	Alkalinity	IS:3025(Pt-23):1986	140	200 Max	600 Max
14.	Magnesium	IS:3025(Pt-46):1986	0.4	30 Max	100 Max
15.	Nitrate	IS:3025(Pt-34):1986	2.3	45 Max	No Relaxation
16.	Nitrite	IS:3025(Pt-34):1986	0.092	45 Max	No Relaxation
17.	Sulphate	IS:3025(Pt-24):1986	18.21	200 Max	No Relaxation

Authorised Signatory

For DIAMOND INDUSTRIES

Hemant

Proprietor

Name :- Hemant Sharma

Date :- 02/03/2025

[Signature]

Principal

Gurukul Public School

Khair (ALIGARH)

Address : Inayatpur Borda , Kolar Road, Bhopal (M.P)